



2025 ROTA WATER QUALITY REPORT

JULY 1, 2026

2025 CUC Rota Water Quality Report

This report is designed to inform you about the water CUC delivers to you, our customer. Our goal is to provide you and your family a safe and dependable supply of drinking water.

Today, 100% of all Rota water customers enjoy 24-hour water service. Our CUC water employees continue to strive to deliver a quality product to all of our customers and to protect the CNMI's water resources.

To ensure the safety of your water, CUC routinely monitors for contaminants in your drinking water according to the CNMI Bureau of Environmental and Coastal Quality (BECQ) and the United States Environmental Protection Agency (US EPA) laws, rules, and regulations

Each year, trained laboratory and water treatment specialists conduct or supervise more than 1,000 tests on Rota water samples. Water quality samples are collected throughout the CUC Rota water system and tested regularly. Samples include untreated and treated water taken from our facilities, sample sites throughout the service areas, and at customers' homes.

Except where indicated otherwise, this water quality report is based on the results of CUC's monitoring for the period of January 1, 2025, to December 31, 2025. Any results reported before January 1, 2025, and presented here, are from the most recent monitoring period.

A Message from the CUC Executive Director

I would like to take this opportunity to share with our valued customers the major accomplishments and ongoing efforts of CUC to deliver reliable, high-quality water service. Each year, we produce an Annual Water Quality Report to keep you informed about the safety and quality of your drinking water.

CUC serves 14 tank areas with 134 wells, one spring, and two Maui wells on Saipan, one Maui well on Tinian, and one spring and three wells on Rota. These systems are supported by the expertise and dedication of our engineers, operators, technicians, laboratory analysts, and administrative professionals, who work diligently to ensure safe and uninterrupted service.

A key priority for CUC is reducing Non-Revenue Water (NRW) - water lost due to system leaks, aging infrastructure, or unauthorized use. Through targeted leak detection, pipeline replacements, system modernization, and the implementation of advanced metering infrastructure, we are strengthening operational efficiency, conserving vital resources, and improving overall system reliability.

With the support of strong partnerships and federal funding from agencies such as the U.S. Environmental Protection Agency (EPA), the Economic Development Administration (EDA), the American Rescue Plan Act (ARPA), the Department of the Interior–Office of Insular Affairs (DOI-OIA), the Northern Marianas Housing Corporation Community Development Block Grant–Disaster Recovery (NMHC CDBG-DR), and the Hazard Mitigation Grant Program (HMGP), CUC continues to advance critical water and wastewater infrastructure improvements throughout the CNMI.

Together, these efforts represent our long-term investment in resilient systems, sustainable operations, and the well-being of the communities we proudly serve.

Kevin O. Watson, MPA
Executive Director





As Matmos, Rota

The Sources of CUC Rota Water

The primary source of water for the island of Rota comes from the one ground water source that is rarely supplemented with groundwater from three (3) deep ground water wells.

To control bacterial contamination in our water, CUC water operators add trace amounts of chlorine added to the water before it goes into the water lines to you, our customer.

How Drinking Water Becomes Contaminated

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.



Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm-water runoff, and septic systems.



Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Contaminants that may be present in source water include:



Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.



Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.



Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses.

In order to ensure that your tap water is safe to drink, the US EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline** at **1 (800) 426-4791** or on the Internet at www.epa.gov/safewater/.

For People with Sensitive Immune Systems

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone an organ transplant, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from health care providers. The US EPA and the Centers of Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available at the **US EPA's Safe Drinking Water Hotline** at **1 (800) 426-4791** or on the Internet at www.epa.gov/safewater/.



From left to right: CUC Rota Water Operators Peter Mendiola, Austin Lizama, Poly Jon Manglona, and Tyric Castro repair a water lateral leak to help reduce water loss





Commonwealth Utilities Corporation Rota

SUMMARY OF PRIMARY DRINKING WATER QUALITY RESULTS FOR 2025



PWS ID: MP0000003

Microbiological Contaminant	Ideal Goal MCLG	Highest Level Allowed MCL	Year Tested	Highest Running Annual Average	Range	Assessments Conducted	Major Source of Contaminant		
Coliform Bacteria	Zero	No more than 1	More than 1 positive sample triggers Level 1 Assessment			2025	1 positive sample in April	NO	Naturally present in the environment
Disinfection Residual	MRDLG	MRDL	Year Tested	Highest Running Annual Average	Range	Violation?	Major Source of Contaminant		
Chlorine (ppm)	4	4	2025	1.0	0.4 - 1.6	NO	Disinfection additive used to control microbes		
Disinfection By-Products	MCLG	MCL	Year Tested	Highest Running Annual Average		Violation?	Major Source of Contaminant		
Total Trihalomethanes (TTHM) Locational Running Annual Average (ppb)	NA	80	2025	0.5		NO	By-product of drinking water disinfection		
Inorganic Contaminants	MCLG	MCL	Year Tested	Highest Result		Violation?	Major Source of Contaminant		
Nitrates + Nitrites as Nitrogen (ppm)	10	10	2025	0.8		NO	Runoff from fertilizer; leaking septic tanks; sewage; erosion from natural deposits		
Radiological Contaminants	MCLG	MCL	Year Tested	Highest Result		Violation?	Major Source of Contaminant		
Adjusted Alpha, Excluding Radon & U (pCi/L)	0	15	2020	3.5		NO	Erosion of natural deposits		
Combined Radium 226/228 (pCi/L)	0	5	2020	0.75		NO	Erosion of natural deposits		
Uranium, Combined (ppb)	0	30	2020	5.2		NO	Erosion of natural deposits		
Lead and Copper at Customer Taps	Action Level Goal	Action Level	Year Tested	90th Percentile	Range 0 sites over Action Level	Violation?	Major Source of Contaminant		
Lead (ppb)	0	15	2025	0.87	ND - 0.96	NO	Corrosion of household plumbing systems and		
Copper (ppm)	1.3	1.3	2025	0.038	0.0022 - 0.041	NO	erosion of natural deposits		

SECONDARY AND UNREGULATED COMPOUNDS DETECTED IN 2025

Compound	Recommended Level	Year Tested	Average Result	Range	Violation?	What This Compound Measures
Chloride (ppm)	250	2025	10.5	10 - 11	NA	Measures the amount of several naturally occurring salts in water
pH	6.5 to 8.5	2025	8.0	7.7 - 8.2	NA	Measures the acidity or alkalinity of water
Sodium (ppm)	NE	2023	5.8	NA	NA	Measures sodium in water from natural deposits or salt water intrusion
Specific Conductance (µS/cm)	NE	2025	293	292 - 294	NA	Measures how well water conducts electricity depending on the amount of dissolved ions
Total Dissolved Solids (ppm)	500	2025	163	160 - 166	NA	Measures amount of minerals dissolved in water
Total Hardness as Calcium Carbonate (ppm)	NE	2025	140	135 - 144	NA	Hardness is the sum of the many forms of naturally occurring calcium and magnesium compounds

NA: Not Applicable NE: None Established

Measurements

Contaminants are measured in:

- ppm: Parts Per Million or milligrams per Liter (mg/L)
- ppb: Parts Per Billion or micrograms per Liter (µg/L)
- pCi/L: Picocuries per Liter - a measurement of radioactivity in water
- µS/cm: micro Siemens per centimeter - a measurement of a solution’s ability to conduct electricity

If the units are hard to imagine, think about these comparisons:

Parts per **MILLION**

1 second in 12 days

1 penny in \$10,000

7 drops of water in bathtub



Parts per **BILLION**

1 second in 32 years

1 penny in \$10 Million

1 drop of water in a swimming pool



Definitions

MCL: Maximum Contaminant Level
The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG: Maximum Contaminant Level Goal
The level of a contaminant in drinking water below which there is no known or expected risks to your health. The MCLG amount allows for a margin of safety.

MRDL: Maximum Residual Disinfectant Level
The highest level of a disinfectant allowed in drinking water. There is evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG: Maximum Residual Disinfectant Level Goal
The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

TT: Treatment Technique
A required process or method intended to reduce the level of a contaminant in drinking water.

AL: Action Level
The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that the utility must follow.

90th Percentile
Statistical value used to determine if Action Level is exceeded. Determined by calculating the value at which 90% of the samples tested were below that value.

Secondary Water Constituents
Not Associated with Adverse Health Effects

Many constituents, such as calcium or chlorides, which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are not regulated by the US EPA or the CNMI Bureau of Environmental and Coastal Quality (BECQ). **These constituents are not causes for health concern.** While secondary constituents are not required to be reported in this document, they may greatly affect the appearance and taste of your water. Hardness is a measure of the amount of calcium and magnesium in the water. Chlorides measure the amount of salts in the water.

The CUC Rota water contains very low amounts of chlorides and has no salty taste. The Rota operators add just enough chlorine to keep the CNMI’s best tasting water safe to drink.

For more information about your water quality,
please call the CUC Water Labratory at
(670) 322-5140.



Bacterial Contaminants

Total Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. Coliform bacteria may occur in the CUC water when the treatment equipment fails, or when leaks occur in the CUC pipelines allowing ground contaminants to enter the pipes. As problems were detected in 2025, the CUC water operators repaired leaks, flushed the water lines, or when needed, added extra chlorine to the water.

Information About Lead

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. CUC Rota is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time.

You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period.

If you are concerned about lead in your water and wish to have your water tested, contact **CUC Rota at 670-664-4282**. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at www.epa.gov/safewater/lead.

Per- and Polyfluoroalkyl Substances (PFAS) Monitoring

The CUC Rota water system was required to monitor for PFAS as part of the CNMI's updated drinking water regulations. **No PFAS constituents were detected in your drinking water.**

PFAS are a group of thousands of synthetic chemicals that have been in use since the 1940s. PFAS have been found in a wide array of consumer and industrial products and as an ingredient in firefighting foam. Current scientific research has shown links between exposure to some PFAS chemicals and adverse health outcomes. Drinking water may be impacted in communities where these chemicals have contaminated the water supply.

You can find more information about EPA's actions to address PFAS in drinking water and links to informational resources at www.epa.gov/pfas.

Information About Nitrates

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider. CUC tests the water in Rota for nitrates at least once per year. The amount of nitrates in all CUC water is below the health effect level.



From left to right: Peter Taitano, Peter Mendiola, and Poly Jon Manglona, CUC Rota Water Operators, work on upgrading the overflow pipe at the 500K Ginalangan Water Reservoir as part of ongoing efforts to improve water system reliability and service for the Rota community.



Call your CNMI Water Regulators and Operators:

Zabrina Shai
Director, BECQ-DEQ
(670) 664-8500

Carson Madrangchar
Acting Drinking Water and
Wastewater Division Manager, CUC
(670) 322-5033

Heidi Yelin
Water Laboratory Manager, CUC
(670) 322-5140

Do You Have Questions?

For more information about your water quality or to find out about opportunities to participate in public meetings, please contact our 24-hour **Call Center** at **(670) 664-4282**.

Checking the Material of Your Water Service Line

CUC is conducting an inventory of water service line material in our system following the U.S. EPA's Lead and Copper Rule Revisions. We must conduct the inventory to comply with the EPA's revised rule.

We need your help to determine the material of your water service line. The property owner is responsible for the service line between the meter and the home. But, we still need to know what your material is.

Submit your results to CUC's Water Service Line Inventory Form:

1. Scan this QR code or type tinyurl.com/4ab4dnp9 into your browser.
2. Fill in all the fields on the form.
3. Click Submit and you will receive an email confirming your submission.



CUC Rota Water Operator Jesse Lizama works to cap an old 6-inch waterline pipe to help minimize water loss, strengthen system operations, and support reliable water service.

Water Outages to Repair Lines

Unscheduled service interruptions occur when operators need to make adjustments or repairs to the water system.

For updates about when water services will be restored, please contact **CUC Customer Service** at **(670) 664-4282**, or the **CUC Rota Office** at **(670) 532-9411**.



CUC Rota Water Operators Austin Lizama and Poly Jon Manglona perform routine maintenance by painting water wells to help preserve infrastructure and ensure reliable system operations.

Pay Your Utility Bill Online or By Phone!

Save time and money by paying your CUC bill online or by phone! You can pay with your Visa, MasterCard, or Discover debit or credit card.

Register your account for online payments at <https://www.twpsay.net/cucgov>.

For payment by phone, please call **1 (855) 729-2282**.

Stay Informed!

For more information and updates, visit us at:

📍 Customer Center
Songsong Village, Rota

☎ (670) 532-9411

🌐 www.cucgov.org



@CommonwealthUtilitiesCorporation



WHAT IS A WATER QUALITY REPORT?



Here is your annual Water Quality Report. It is about the water supplied by the Commonwealth Utilities Corporation. In 1996, the U.S. Congress amended the Safe Drinking Water Act and now requires that the CUC, your “Community Water System,” publish this report before July 1. **This report contains important information about your drinking water. Speak with someone who understands it or who can translate it.**

We hope you read about the source of your water, the levels of detected contaminants, why our water is so different from village to village, and what is being done to correct or improve water services in the CNMI.

As consumers become better informed, they become involved and make better decisions about our environment, how money is spent, and our options in water utility management.

If you need the report translated, wish to speak with someone about the report, or would like a paper copy delivered or e-mailed to you, please call CUC at (670) 664-4282.

Estagui i kada sâkkan na iyon-miyu Ripot Kuâlidât Hânum. Esti na ripot put i hanum na i Commonwealth Utilities Corporation ha nânnâ'i hamyu, i iyon-mâmi customer. Gi 1996, i Kongresun Estâdus Unidus ma'amenda i Âkton Sinâfu' Magimin Hânum ya pâ'gu magagâogâo i CUC, i iyon-miyu “Sisteman Hânum Kumunidât” para u pupblisa esti na ripot ântis di Huli 1. **Esti na ripot ha sasahguan manimpottânti siha na infotmación put i magigimin na hânum-miyu. Kuentus yan ottru na tâotâo ni kumumprendi osino i hâyi siña umintetpiti i infotmación para hâgu.**

In diseseha na un taitai put ginen manu i hanum-miyu, i “levels” i mantinatmi ni masodda', hâfa na i hanum-ta na manggof difirensiâo gi kada songsong asta ottru songsong, yan hâfa macho'cho'gui para u mana'dinanchi pat mana'ke'mâolik i sitbisiun i hanum siha gi halum iya CNMI.

Komu i “consumers” manininfotman mâolik, siempri mañaonâo yan mama'tinas la'mâolik na disisión siha put i uriyâ-ta, taimanu i salâppi' magâsta, yan i inayek-ta siha gi minanehan “utility” hânum.

Yanggin un nisissita i ripot matrânsládâ, ya malagu' hâo para un kuentusi hâyi put i ripot, pat malagu' hâo mahanâogui kopian pâppit osino para u ma- “e-mail” kopia guatu giya hâgu, put fabot âgang i CUC gi (670) 664-4282.

Iyeel yóómw arongorong reel Water Quality ghal ráagh. Mileel nge reel schaal iye Commonwealth Utilities Corporation re ayooraí ngálúgh, lemám customer. Liól 1996, U. S. Congress re liiweli mille Safe Drinking Water Act nge ighila re tipáli bwe CUC, yóómw “Community Water System,” bwe ebwe ghommwal akkatééwow arongorong yeel mmwalil Uliyo 1. **Eyoor impotantil arongorong yeel reel schaal iye si ghal úlúmi. Kkapas ngáli iyo mwu e metaff me ebwe bwal affata ngálúgh reel mileel.**

Ai ghal tettengágh ngáli ghámi bwe ów bwe árághi milikka e toowow bwe arongorong reel schaal iye yóómw, level reel milikka re schúngi bwe mil nngaw, meta bwulul bwe schaal ese weewe me schaalil sóóbw ikka akkâw, me meta iye emmwel sibwe féérú ngáre siiweli bwe ebwe ghatchúló aar alilis reel schaal liól CNMI.

Ngáre re aronga ghatchúr consumers, emmwel rebwe schuu bwe rebwe ppwol fengál reel mwóghutughut ikka e lo weleórosch, efaisúl re yááli selaapi, me sibwe áffilighatch reel mwóghutughutúl mille “water utility management”.

Ngare eyoor arongorong iye u mwuschel rebwe seleti, ngare u mwuschel kkapas ngáli escháy reel arongorong yeel, me ngare u mwuschel rebwe afanga ngare e-mail ngalúgh pappid yeel, fafailó CUC reel (670) 664-4282.

Naglalaman ang report na ito ng importanteng impormasyon tungkol sa iyong iniinom na tubig. Magkaroon ng isang tao na isasalin ito sa iyong wika para sa iyo, o makipag-usap sa isang tao na nakakaintindi dito.

此报告包含有关您的饮用水的重要信息。请人帮您翻译出来，或请看懂此报告的人将内容说给您听。

このレポートには飲料水に関する重要な情報が記載されています。この英文を訳してもらるか、またはどなたか英語が分かる方にたずねてください。

이 보고서에는 귀하의 식수에 대한 중요한 내용이 실려있습니다. 그러므로 이 보고서를 이해할 수 있는 사람한테 번역해 달라고 부탁드립니다.





CUC Rota Office
P.O. Box 1166
Sinapalo Village
Rota, MP 96951

 (670) 532-9411

 cucadmin@cucgov.org